



NCPWB

WELDER PERFORMANCE QUALIFICATIONS

POLICY & PROCEDURE

[illegible]

**NATIONAL CERTIFIED
PIPE WELDING BUREAU**

“TESTING EVENT”

POLICY & PROCEDURE

“TRAINING PROGRAM”



NCPWB POLICY & PROCEDURE

A tutorial for the Contractor when participating in a Joint Welder Qualification testing event with the United Association Welder Certification Program

S
I
i
d
e
4

S
I
i
d
e
5

S
I
i
d
e
6



As the NCPWB member contractor present during United Association welder/brazer qualification testing, you are satisfying the requirements in ASME Section IX, Para. QW-300.2 and QB-300.2, which states in part that
“...welders/brazers or welding operators/brazing operators...shall be tested under the full supervision and control of the manufacturer, contractor, assembler or installer...”



The NCPWB Technical Committee has ***recommended*** and the NCPWB Board of Trustees has ***approved*** the following to be followed by the participating contractor.



NCPWB

WELDER PERFORMANCE QUALIFICATIONS
IN-PROCESS RESPONSIBILITIES

SECTION – I.



I. CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING A TESTING EVENT

Whenever a welder/brazer is tested, there shall be a NCPWB member contractor present in the facility where the test coupon will be welded/brazed. This person shall be a regular paid employee of a NCPWB contractor. This contractor shall work together with the UA Authorized Testing Representative (ATR) in administering the test.



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

The following tasks shall be performed by the contractor in coordination with the UA Authorized Testing

Representative (ATR) prior to and during the welding/brazing of the test coupon/coupons:



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

1.) Verify the **identity** of the welder/brazer using the picture I.D. and other documentation the welder/brazer has provided to the ATR during the joint test session briefing and roll call.



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

2.) Verify that the welder/brazer has access to a copy of the applicable Welding/Brazing Procedure **Test Specification** (WPS) (BPS) that the welder/brazer will follow during welding/brazing of the test coupon.



UA-63 WELD TEST SPECIFICATION

Manual GTAW/SAW Welding Processes

MAXIMUM TIME PERMITTED FOR TEST IS 5 HOURS

PIPE COUPON MATERIAL

- Specification of Base Metal(s): SA 106
- Pipe Size: 2.750" O.D. Thickness: 0.625" Wall

JOINT CONFIGURATION

- Single Vee Groove without backing or retainers
- Bevel: 35 deg. $\pm$ 5 deg. Land: 0 to $\frac{1}{8}$ "
- Root Gap: $\frac{1}{16}$ " to $\frac{1}{8}$ "
- Misalignment: $\frac{1}{16}$ " maximum

TEST POSITION

- 6G fixed position, coupon position maintained without rotation or change in height
- Uphill progression required on vertical portions of weld joint

WELDING CONDITIONS

ROOT

- ER 70S-2 $\frac{3}{32}$ " or $\frac{1}{8}$ " Diameter
- Deposit 0.125" of ER 70S-2
- Amperage Range: $\frac{3}{32}$ " 65 to 95; $\frac{1}{8}$ " 75 to 125
- Direct Current & Electrode Negative
- Pulsing current not permitted
- Tungsten: EWTh-2 or EWCe-2, $\frac{3}{32}$ " or $\frac{1}{8}$ " Diameter
- Cup Size: #4 through #12
- Shielding Gas: Argon @ 8 to 35 CFH
- Backing Gas or Trailing Gas is not permitted

BALANCE

- E 7018 $\frac{3}{32}$, $\frac{1}{8}$, or $\frac{5}{32}$ " Diameter
- Amperage Range: $\frac{3}{32}$ " 70 to 100; $\frac{1}{8}$ " 115 to 165; $\frac{5}{32}$ " 150 to 220
- Direct Current & Electrode Positive
- Deposit a minimum of three layers

GENERAL WELDING TECHNIQUES

- Minimum Preheat of 50° F is required.
- Back gouging of welds is not permitted.
- I.D. Root Penetration: flush to $\frac{1}{8}$ " maximum
- O.D. Reinforcement: flush to $\frac{3}{16}$ " maximum
- Stringer beads required for root pass, subsequent passes may be stringer or weave beads
- Initial & interpass cleaning with brushing & grinding using hand or power tools
- The cover pass must be left in the "as welded" condition, clean with wire brush, (grinding or filing on the completed test coupon is not allowed)

INSPECTION AND TESTING

- The completed test assembly shall be visually examined over the entire circumference, inside and outside, showing complete joint penetration with complete fusion of weld metal and base metal (no concavity); and shall be uniform and free of cracks, incomplete fusion, incomplete penetration, porosity, slag, and undercut (not to exceed $\frac{1}{32}$ "
- Test coupon shall be examined by radiography in accordance with ASME Code Section IX



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

3.) Verify that the welder/brazer has access to a copy of the applicable **UA Testing Event Inspection Report**. This document covers the in-process inspection hold points, locator stamp, tack welds, start and finish times and requires signatures of both the participating contractor and the ATR.

S
l
i
d
e

1
6

S
l
i
d
e


1
7

S
l
i
d
e

1
8



DO NOT PROCEED WITHOUT THE "T" STAMP



A LOCATION MARKER OR "T" STAMP AT 12 O'CLOCK



TEST ASSEMBLY IDENTIFICATION NUMBER

6.) Verify that the test coupon is marked with the welder's/brazer's test assembly I.D. number. e.g., **63CS4567**

63 = UA Test
CS = First & Last initials
4567 = Last four of UA ID#



VERIFY MARKING OF THE TEST
ASSEMBLY IDENTIFICATION NUMBER
ON THE TEST ASSEMBLY

28 RW 1123

S
l
i
d
e
1
9




CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

7.) Verify that the **electrode** or **filler** metal type to be used for the root and fill passes are correct and are used in proper sequence in accordance with the UA Weld Test Specification.

S
l
i
d
e
2
0



SMAW-----
PRINTED



-----GTAW
STAMPED

S
l
i
d
e
2
1



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

8.) Verify with the UA Weld Test Specification that the direction of **weld progression** is correct.

Verify with the UA Weld Test Specification that the coupon is in the correct **test position**.

e.g., 1-G, 2-G, 5-G, or 6-G

S
l
i
d
e

2
2


S
l
i
d
e

2
3

S
l
i
d
e

2
4

**1G or 1-GR "ROLLED" WELDING ON TOP
PIPE HORIZONTAL**



**2-G HORIZONTAL WELDING,
PIPE VERTICLE**



**5-G VERTICLE WELDING
PIPE HORIZONTAL**



6-G 45 DEGREE INCLINED WELDING PIPE @ 45 DEGREE ANGLE



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

9.) Verify with the UA Weld Test Specification that the **selected amperage** is within ranges specified by the WPS. Wire feed speed, voltage, polarity and current can also be verified on this specification document.



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

10.) Verify approximate thickness of the **weld metal deposited** with each process and filler metal type when more than one process or filler metal type is used.

Deposited weld metal ranges may be found on the UA Weld Test Specification or Welder Qualification Record.

S
I
i
d
e

2
8



UNITED ASSOCIATION

WELDER QUALIFICATION RECORD

First Name

MI

Last Name

UA Card Number

ATF Local

Sampling No.

Test Date

TESTING CONDITIONS

Weld Test Specification followed: UA-63 / NCPWB 1-32-1

Specification of Base Metal(s): SA 106 Thickness: 0.625"

QUALIFICATION LIMITS

WELDING VARIABLES	ACTUAL VALUES		RANGES QUALIFIED	
	GTAW	SAW	GTAW	SAW
Backing	none	weld metal	with or without	required
Use of Filler Metal	with	n/a	required	n/a
Filler Metal Product	solid	n/a	solid or metal	n/a
Filler Metal E-Number	S	A	S	A, S, 2, 1
Consumable Inserts	none	n/a	without	n/a
Deposited Weld Thickness	0.125"	0.500" deposited over 3 layers	up to 0.250"	unlimited
Inert gas backing	none	n/a	with or without	n/a
Current / Polarity	DC/EN	n/a	DC/EN	n/a
Pipe Diameter	2.750" O.D.		1" O.D. & over	
Base Metal P-Number	P-1 to P-1		P-1 through P-11	
Position	6G		all	
Vertical Progression	upward		upward	

EXAMINATION RESULTS

ATF Visual Examination of Completed Weld (QW-302.4): Acceptable

Test Lab Radiographic Examination Results (QW-191): Acceptable

Lab Test Report

We certify that the statements in this record are correct and that the test coupons were prepared, welded, and tested in accordance with requirements of Section IX of the ASME Code.

Test Lab Company Name

Test Lab Representative Signature

Date:

UA Authorized Test Facility Local Number

UA Authorized Test Representative Signature

Date:

Manufacturer/Contractor Company Name

Manufacturer/Contractor

Date:

S
I
i
d
e

2
9



CONTRACTOR'S & ATR'S

RESPONSIBILITIES DURING TESTING

11.) Verify **proper backing gas** and flow rates; torch and weld head gas and their **proper mixtures**, including flow rate ranges, can also be found on the UA Weld Test Specification sheet.

S
I
i
d
e

3
0



CONTRACTOR'S & ATR'S

RESPONSIBILITIES DURING TESTING

12.) The cover pass must be left in the "as welded" condition, cleaning with power or hand wire brush is allowed, (**grinding or filing on the completed test coupon inside or outside is not allowed**).

Per UA Weld Test Specifications



13.) **Safety Check:** a continuous safety check for required Personal Protective Equipment is critical. The testing area shall have **Adequate Ventilation** and be protected from the elements.

[illegible]

14.) “If at anytime during a weld test the ATR or Contractor Representative determines the welder **does not demonstrate** the necessary welding skills the weld test shall be terminated.”



WELDER/BRAZER PERFORMANCE QUALIFICATIONS CONDUCTING VISUAL EXAMINATIONS

SECTION – II.




II. CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING A TESTING EVENT

After the welder has completed welding any portion of the test coupon and has called for inspection, the Contractor and the UA Authorized Testing Representative (ATR) shall **Visually Examine** the entire test coupon inside and outside for the following:




Undercut (not to exceed 1/32")
and Overlap / Cold Lap
(none permitted)



Incomplete Fusion (none permitted)

- a.) in the root.
- b.) in the side wall.
- c.) on the cover pass.



S
l
i
d
e


3
7

3
8

3
9




Root Concavity / Suck Back (none permitted)





Underfill and Incomplete Joint Penetration (none permitted)





Cracks (none permitted)



S
l
i
d
e

4
0

S
l
i
d
e


4
1

S
l
i
d
e

4
2



Porosity (none permitted)





Slag (none permitted)
Trapped / Included






Weld Reinforcement
“per UA Weld Test Specifications”

FACE / O. D.
REINFORCEMENT

FACE OF
WELD

ROOT / I. D.
REINFORCEMENT





CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

"If at anytime during a weld test the ATR or Contractor Representative determines the welder **does not demonstrate** the necessary welding skills the weld test shall be terminated."



NCPWB

WELDER/BRAZER PERFORMANCE QUALIFICATIONS
CONTINUITY UPDATES

SECTION – III.



III. CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING CONTINUITY UPDATES

ASME SECTION IX – QW-322.1a
"When a welder or welding operator has not welded with a process during a period of six months or more, his qualifications for that process shall expire."



III. CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING CONTINUITY UPDATES

ASME SECTION IX – QW-322.1(1)
*“when the welder has welded with that process
under the supervision and control of the
qualifying manufacturer or contractor or
participating organization that will extend his
qualifications for an additional 6 months.”*



WELDER QUALIFICATION CONTINUITY UPDATES

UA WCP Quality System Manual:

*“when unable to maintain continuity from an
Employing Manufacturer/Contractor,
continuity updates may take place at any UA
Authorized Testing Facility and must be
supervised by an ATR and at least one
Manufacturer / Contractor Representative.”*



WELDER QUALIFICATION CONTINUITY UPDATES

UA WCP Quality System Manual:

*“the continuity demonstration shall consist of
welding a minimum of one complete pass for
each welding process they are qualified in,
using a pipe coupon, in accordance with a UA
Weld Test Specification applicable to the
welding process involved.”*

S
I
i
d
e

4
9

5
0

S
I
i
d
e

5
1



WELDER QUALIFICATION CONTINUITY UPDATES

UA WCP Quality System Manual:

*“the continuity report lists the Welder’s name,
last date each welding process was
demonstrated by the individual and is signed
and dated by the supervising Representative
of the Employing Manufacturer/Contractor.”*



UA WELDER QUALIFICATION CONTINUITY REPORT

Welder's Name										L R O B E R T S									
UA Card Number										UA Testing Local									
0 8 7 6 0 5 4 3 2										1 6 8									

WELDER CONTINUITY INFORMATION																			
Indicate the last date the process was used																			
SMAW: 0 2 / 2 8 / 0 7										* Manual Welding									
GTAW: 0 3 / 0 8 / 0 7										* Manual Welding									
GMAW: 0 3 / 1 2 / 0 7										* This includes Flux-Cored Arc Welding (FCAW)									
Automatic or Machine Welding (GTAW):										* This includes orbital welding									
Torch Brazing:										* Non Med-Gas									

We certify that the statements made on this record are correct:

Ohio Fabricators Ltd.	
Manufacturer/Contractor Company Name	
<i>Leonard Walker</i>	<i>March 14, 2007</i>
Signature of Company Representative	Date Signed
Leonard Walker, QC Manager	
Printed Name & Title of Company Representative	
Local Union 168	
UA Local Union Number	
<i>Robert Burton</i>	<i>March 14, 2007</i>
Signature of UA ATR	Date Signed
Robert Burton	
Printed Name of UA ATR	

Mail To: The UA Testing Local shown above, ATTN: UA Authorized Testing Representative



CONTRACTOR'S & ATR'S RESPONSIBILITIES DURING TESTING

“If at anytime during a continuity update the
ATR or Contractor Representative determines
the welder **does not demonstrate** the necessary
welding skills the continuity update shall be
terminated.”

S
l
i
d
e

5
2



NCPWB

WELDER/BRAZER PERFORMANCE QUALIFICATIONS

THE END

QUESTIONS & ANSWERS
